

# TOWN BUILDINGS COMMITTEE

## DRAFT MINUTES

MAY 30, 2017

MEETING STARTS AT 6:05 PM

MEMBERS PRESENT: NANCY MATTHEWS, BOB GROVES, JIM AARON  
GUEST: MIKE VINSKEY

MINUTES FROM 4/12/17 READ AND APPROVED

### **DISCUSSION ABOUT SCHOOL ROOF**

LEAKING IN OFFICE ADJACENT TO NW CORNER OF GYM AND VARIOUS LOCATIONS AROUND BUILDING.  
LEAK IN OFFICE/GYM HARD TO DIAGNOSE.  
HAYDEN FIXED POPPED NAILS AND REINFORCED FLASHING AROUND SCUPPER NEAR WINDOW WHICH IS LEAKING. HAYDEN ALSO CAULKED WINDOW FLASHING.  
WINDOW LEAK PERSISTS IN HARD RAIN.  
BOB WILL TRY TO GET TO SEE LEAK IN ACTION DURING RAIN.  
BOB AND BRIAN H VISITED SCHOOL ON 5/26. DURING RAIN AND OBSERVED WATER COMING OUT OF BLOCK WALL ABOVE WINDOW FLASHING.  
GUTTER APPEARS TO BE PROPERLY FLASHED.  
BRIAN WILL WORK MORE ON ROOF AROUND SCUPPER.

BILL WILL CALL FCOG AND UNION 28 TO ENQUIRE ABOUT GRANT FOR ROOF JOB.

BOB WILL CALL AMHERST.

BOB WILL CALL BOB LEET..

TUES 6/6 AT 5:30 BC MEET AT SCHOOL, GO TO HIGHWAY DEPT.

OTH

TIM TOOK TREES DOWN.

MIKE RECOMMENDS BC DRAW UP SCOPE OF PROJECT DOC . BOB WILL  
LOOK AT HIS OLD ONE AND MODIFY IT AS NEEDS BE.

BOB WILL BRING TO NEXT MEETING

BC WOULD LIKE HIST COM TO SUPPORT PROJECT

JIM SUGGESTS THAT PART OF OTH COULD BE RESERVED FOR HIST COM

BOB STATES THAT THIS IDEA HAS BEEN PROPOSED TO THEM

TOWN HALL

BATHROOM STENCH. URINAL REMOVED, TOILET REPLACED.  
STENCH REMOVED?

DOC STORAGE

COMMITTEE FORMED BY SB

BC MEMBER ON COMMITTEE

TOWN NEEDS INCREASED CAPACITY NOW AND IN FUTURE.

NEW CAPACITY WILL RELIEVE PRESSURE ON OTH.

MEETING ADJOURNS 7:05.